

2016

Water Quality Report

Monticello Water Treatment Facility

ID NO. GA1590000

Welcome to the City of Monticello's annual water report. This government required report contains important information on the quality of water distributed to you, our customer, in 2016. Water is supplied to the plant from the Monticello Reservoir and three wells. Well water and reservoir water are combined and treated at the water plant. The City of Monticello's water treatment plant monitors water according to state and federal regulation; we also monitor the water quality on a continuous basis through operator testing during plant operation to maintain the highest level of water quality possible.



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800)426-4791. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels

over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agricultural, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes or petroleum production, can also come from gas production, can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulates established limits for contaminants in bottled water that must provide the same protection for public health.

Concerning Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant

women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Monticello is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the:

Safe Drinking Water Hotline

At 1-800-426-4791 or

<http://www.epa.gov/safewater/lead>

A source Water Assessment Plan identifies the watershed that contributes to your drinking water, potential sources of contamination and how susceptible your water is to contamination. You can request information about this assessment from the City of Monticello by phone at 706 468-8834, located at 123 W. Washington Street or P.O. Box 269, Monticello, Georgia 31064 or you may choose to attend regular city council meetings held the second Tuesday of each month at City Hall. Your drinking water is processed by certified operators that are skilled in the knowledge of water treatment, dedicated to deliver you quality first and proud of our water as it comes from the tap.

City of Monticello

P. O. Box 269

Monticello, GA 31064

706-468-8834 www.monticelloga.org

2016 Detected Contaminants Table

<i>Regulated Contaminants</i>							
Substance	MCL	MCLG	Monticello's Water System Results	Detected Range	Is the water safe?	Test Year	Typical Sources of Contaminant
<i>Microbiological Contaminants</i>							
Filtered Turbidity	TT = 0.15 NTU 95 % Samples ≤ 0.30 NTU	.30 NTU	0.07 NTU	0.03 - 0.27 NTU	YES	'16	soil runoff
Total Coliform Bacteria	5% of Samples Positive	0% Positive	0% Positive	0% Positive	YES	'16	naturally occurring
Total Organic Carbon	TT 35% Removal	TT 35% Removal	1.40 ppm	1.1 – 2.0 ppm	YES	'16	naturally occurring
<i>Disinfection & Disinfection By-products</i>							
Total Trihalomethanes	80.0 ppb/RAA	64.0 ppb	RAA 44.5 ppb	35.5 – 44.5 ppb	YES	'16	treatment process by-product
Haloacetic Acid	60.0 ppb/RAA	48 ppb	RAA 38.6 ppb	26.6 – 38.6 ppb	YES	'16	treatment process by-product
Chlorine	4 ppm	4 ppm	1.49 ppm	0.42 – 2.51 ppm	YES	'16	water additive used to control microbes
<i>Inorganic Contaminants</i>							
Fluoride	4 ppm	4 ppm	.86 ppm	0.71 - 1.20 ppm	YES	'16	water additive which promotes strong teeth
Nitrate	10 ppm	10 ppm	ND	N/A	YES	'16	erosion of natural deposits
Substance	Action Level	MCLG	Monticello's Water System 90th Percentile	Number of Samples Above Action Level	Is the water safe?	Test Year	Typical Sources of Contaminant
Copper	1300 ppb	N/A	320 ppb	0	YES	'16	household piping
Lead	15 ppb	N/A	3.5 ppb	0	YES	'16	household piping

DEFINITIONS

MG: Million Gallons

MGD: Million Gallons per Day

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The highest level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Running Annual Average (RAA): The arithmetic average of the four most recent quarterly results.

Treatment Technique (TT): A required process intended to reduce the level of contaminant in drinking water.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Nephelometric Turbidity Unit: (NTU): a measure of the cloudiness of water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

ppm or mg/L: parts per million or milligrams per liter. One part per Million is the equivalent of one minute in 2 years or one penny in 10 thousand dollars.

ppb or ug/L: parts per billion or micrograms per liter. One part per billion is the equivalent of one minute in 2,000 years or one penny in 10 million dollars.

N/A: Not Applicable